

# Compliance Statement

No. 2025-161

## Screened Permanent Link, Class E<sub>A</sub>

### Company

DECELECT  
1 rue des Fondateurs  
02200 SOISSONS  
France

### Permanent Link Identification (2 connector model)

LIEN PERMANENT CAT6A

### Horizontal cable:

Cat 6A U/FTP; Part no. TC500U/FTPI6AOH

### RJ45 connector for telecommunications outlet and patch panel:

Screened RJ45 connector; Part no. DC6A10G

### Generic cabling standards - Class E<sub>A</sub> Permanent Link requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

### Technical report

12434626-01, DANAK-19/24858

### EC Cabling product ID


6845

### CS valid until

1 April 2026

This product has been tested by FORCE Technology and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 12 March 2025



Lars Lindskov Pedersen  
Test Manager



Dennis Andersen  
Head of Department

